



ENGINEER

EVALUATE

TEST

CONSULT

**ROOF SYSTEM ASSESSMENT REPORT  
 DYNAMIC UPLIFT RESISTANCE PER CSA A123.21**

CLIENT:	SEAMAN CORPORATION	TEST DATE:	2020-02-12
DOCUMENT NO.	SMN-AARS-6	PUBLICATION DATE:	2020-12-29
TEST PANEL NO.	SMN-D12	REVISION NO.	1
SYSTEM TYPE:	A-1	REEVALUATION DATE:	2023-02-12

**ADHESIVE APPLIED ROOFING SYSTEM (AARS) SUMMARY**

PERFORMANCE⇒	PASSING PRESSURE	WIND UPLIFT RESISTANCE (with SF of 1.5)
	3.6 kPa (75 psf)	2.4 kPa (50 psf)

COMPONENT	ALLOWABLE PRODUCTS		BY
MEMBRANE⇒	<u>Option #1</u>	<u>Option #2</u>	Seaman Corporation
	FiberTite, FiberTite-SM, FiberTite-XT or FiberTite XTreme	FiberTite FB, FiberTite-SM FB, FiberTite-XT FB or FiberTite XTreme FB	
ATTACHMENT:	<u>For Option #1</u>	<u>For Option #2</u>	
	FTR-190e, contact application, 0.5 gal./sq. per surface	FTR-290 or FTR-390 at 1 gal./sq.	Seaman Corporation
		Polyset CR-20, spatter-application	ICP Adhesives & Sealants
INSULATION, TOP LAYER⇒	max. 4 x 4-ft. x min. 1.5-inch thick		
	FTR-Value or FTR-Value H		Seaman Corporation
	ACFoam II		Atlas Roofing
	H-Shield		Hunter Panels
	ISOLEX A		Lexusco 2010 Corp
ATTACHMENT:	FTR-601	ribbons 12-inch o.c.	Seaman Corporation
	FTR-601 PG	ribbons 12-inch o.c.	Seaman Corporation
	Millennium One Step Foamable	ribbons 12-inch o.c.	H.B. Fuller
	Millennium PG-1 Pump Grade	ribbons 12-inch o.c.	H.B. Fuller
	Insultac II Insulation Adhesive	ribbons 12-inch o.c.	Lexusco 2010 Corp
	Insultac II Pump Grade Insulation Adhesive	ribbons 12-inch o.c.	Lexusco 2010 Corp

**ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21**

CLIENT: SEAMAN CORPORATION PUBLICATION DATE: 2020-12-29  
 DOCUMENT NO. SMN-AARS-6 REVISION NO. 1  
 TEST PANEL NO. SMN-D12 REEVALUATION DATE: 2023-02-12  
 Page 2 of 2



COMPONENT	ALLOWABLE PRODUCTS	BY
INSULATION, BASE LAYER(S)⇒	Optional, one or more layers, max. 4 x 4-ft. x min. 1.5-inch thick	
	FTR-Value or FTR-Value H	Seaman Corporation
	ACFoam II	Atlas Roofing
	H-Shield	Hunter Panels
	ISOLEX A	Lexsuco 2010 Corp
	ThermalStar TS	Atlas Molded Plastics
	ISOZOL EPS	Fransyl
ATTACHMENT:	FTR-601	ribbons 12-inch o.c. Seaman Corporation
	FTR-601 PG	ribbons 12-inch o.c. Seaman Corporation
	Millennium One Step Foamable	ribbons 12-inch o.c. H.B. Fuller
	Millennium PG-1 Pump Grade	ribbons 12-inch o.c. H.B. Fuller
	Insultac II Insulation Adhesive	ribbons 12-inch o.c. Lexsuco 2010 Corp
	Insultac II Pump Grade Insulation Adhesive	ribbons 12-inch o.c. Lexsuco 2010 Corp
VAPOUR BARRIER⇒	Option #1: VaporTite	Seaman Corporation
	Option #2: FiberTite-SBS TG Base or FiberTite-SBS 190 TG Base	Seaman Corporation
ATTACHMENT:	For Option #1: self-adhering	
	For Option #2: torch-applied	
PRIMER⇒	For Option #1: ELASTOCOL Stick Zero, 1 gal./100 ft2	Soprema
	For Option #2: ASTM D41 primer, 0.5 gal./100 ft2	various
DECK⇒	Min. 2,500 psi structural concrete generic	

NEMO ETC CREDENTIALS		
TYPE	ENTITY	REFERENCE
ISO/IEC 17025 Accreditation	International Accreditation Service (IAS)	TL-689
TAS 301 Certification	Miami-Dade	17-1214.02
Third Party Test Data Program	UL, LLC	DA2862
Test Lab Listing	Roofing Contractors Association of British Columbia	<a href="http://www.rcabc.org">www.rcabc.org</a>

REPORT HISTORY			
DATE	EVENT	NOTES	AUTHORIZED BY:
2020-08-24	FINAL issued	After client review	RN
2020-12-29	REVISION 1 issued	Add Insultac II Insulation Adhesive and Insultac II Pump Grade Insulation Adhesive Add ISOLEX A Correct Option #2 membrane designations.	RN

This report and the data contained therein is the sole property of NEMO|etc. and the named client. This report shall not be reproduced outside NEMO|etc. except by the named client without written permission by the named client, in which case the report shall be reproduced in its entirety.

**END OF REPORT**